

Engineering & Utilities Policy & Procedure #10

TITLE:

CERTIFICATIONS OF WATER BACKFLOW PREVENTERS (BFP) AND FIRE HYDRANTS

OBJECTIVE AND PURPOSE:

- ◆ The purpose of this policy is to protect the university water supply from contamination through proper inspection, testing and maintenance of backflow prevention systems. It is also to ensure that fire hydrants are operating properly and are disposing water as needed during a fire emergency.
- This policy also provides guidelines and procedures for the testing, repair and certification of backflow devices and fire hydrants in accordance with Florida Statutes 633.5391, NFPA 25, City of Boca Raton Ordinance and other requirements established by the local authorities as it applies to the specific apparatus.
- In accordance to the above regulations fire hydrants and back flows shall be tested annually by certified contractor to ensure proper operation.

RESPONSIBILITY:

ACTION

DIRECTOR OF ENGINEERING & UTILITIES

- Designate a qualified person to manage backflow prevention devices and fire hydrants.
- Allocate budget and other necessary resources to manage the program.
- Ensure that the university is in compliance with the maintenance of the apparatus.

PROGRAM MANAGER

- Establish system, guidelines, policies and procedures to properly manage backflows and fire hydrants by following recommended practices.
- Following university procedures hire certified contractors to perform inspection, testing and maintenance on the systems as required by regulations.
- Coordinate portable and non-portable water outages with end users, physical plant and EH&S.
- Ensure that auxiliary buildings and lease holders such as Community College and Research Park are charged for the maintenance of the systems that service their corresponding areas.
- Maintain a database of fire hydrants and backflow prevention devices and ensure Infrastructure Plan is updated regularly.
- Review inspection reports and take corrective action when necessary. Inspection reports are submitted by contractors using the attached forms.
- Maintain files of completed annual inspection reports.
- Transmit records to responsible FAU departments or other agencies as appropriate. Annual fire hydrant reports are submitted to EH&S on a timely basis.
- Review inspection reports to ensure all hydrants are operational and pressure test records match with the color coding of the hydrant. Install out of service sign if reported defective.

ENVIRONMENTAL HEALTH AND SAFETY

- Transmit fire hydrant flow test report to the local Fire Department.
- ◆ Fire Hydrant Inspection Report Form A, and Backflow Prevention Insp. Report Form B

ATTACHMENTS

- ◆ Fire Hydrant Inspection Report Form A Attachment "A"
- Backflow Prevention Inspection Report Form B Attachment "B"

Issued By: J. Baker	Date Issued: 1/2007	Date Revised:	Effective Date: 1/2007
APPROVED:	Vice President	Associate V.P.	Director



ENGINEERING & UTILITIES FIRE HYDRANT REPORT

FORM A

HYDRANT AND WATER SUPPLY SYSTEMS INSPECTION AND MAINTENANCE REPORT						
Fire Hydrant Location:			Hydrant #			
Fire Hydrant Model:	riyaranc #					
INSPECTION						
Semi-annual Dry Barrel Hydrants						
			RY NO = UNSATISFACTORY			
,		YES	NO			
Hydrants are accessible			-			
Hydrant outlets are slightly more than hand-tight						
There are no leaks in the top of the hydrant						
There are no leaks in the gasket under the caps						
There are no cracks in the hydrant barrel						
Hydrant drains properly (dry barrel hydrants)						
Operating nut is not worn and does not have rounde	d corners					
Nozzle threads are not damaged						
Check hose houses to assure all equipment is in goo	od condition					
Turns to open (enter number of turns to open fully)						
7						
MAINTENANCE		YES	NO			
Lubricate Operating Nut						
Lubricate Packing						
Lubricate Thrust Collar						
WATER SUPPLY SYSTEMS FLOW TEST						
Water distribution systems: Annual test is accon	nplished during fire hy	drant ann	ual test.			
For each test, record the following:						
Residual hydrant location	#					
Flow hydrant location	#					
Static pressure (residual hydrant)			psi			
Residual pressure (residual hydrant)			psi			
Pitot pressure (flow hydrant)		psi				
Nozzle size (flowing nozzles only)			inches			
Nozzle coefficient (flow hydrant)			T = =			
Measured flow (GPM)			GPM			
Calculated available flow at 20 psi			GPM			
COMMENTS						
	A\A\\\ CO\	OD CODE.	1			
Company: Certified B	AWWA COI					
Certified B	acanow i iolection, iii	Date.				
Performed by: Print name						
Sign:						
Sign.						



ENGINEERING & UTILITIES

APPENDIX B

BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE RECORD								
I.	General Information							
	Address: Location of assembly:	Date of Ins	tallat	ion:	Ir	ncoming line pressure:		
	Location of assembly.		Date of Illo	Date of Installation:			nooning line pressure.	
Manufacturer			Model #:	Model #:			Serial #:	
Size:			Assembly t	Assembly type:				
			RP RP detector			tor	DC detector F	PVB
II.	Test and Repairs information							
	Check valve #1		Check val	ve #2	2		Differential pressu relief valve	re
Initial Test	Leaked	Leaked			Ir	Opened at	psid	
ΙL	Closed tight	=	Closed tight				Did not open	
ıiti	_		e drop acros	s the	second		•	
_	check valve ispsid	ch	eck valve is		p:	sid		
Repairs	List repairs and corrections	LIS	t repairs and o	сопес	CHOIS		List repairs and correcti	OHS
Final test	Closed tight	Clo	sed tight				Opened at	psid
	Condition of No.2 control valve:	Clos	sed tight] L	eaked	
Remarks:		Assembly failed			A	Assembly passed		
III. A	Approvals							
" I hereby certify that this data is accurate and reflects the proper operation and maintenance of the assembly and that all control valves were left in the full open position."								
Name of certified technician		Technician phone#		N	Name of Witness to test:			
Signature of certified technician			nician Date cation #			Witness phone #		